

# Pinnacle Series

## SELECT PIVOT DOOR

## SPECIFICATIONS

### PART 1 - GENERAL

#### 1.01 SECTION INCLUDES

- A. Factory assembled aluminum/aluminum and aluminum/wood pivot doors, optional glass and glazing, operable hardware, weatherstripping and [grilles].
- B. Anchorages, attachments, and accessories.

#### 1.02 RELATED SECTIONS

- A. Section 01340 - Shop Drawings, Product Data, and Samples.
- B. Section 01610 - Delivery, Storage, and Handling.
- C. Section 01710 - Final Cleaning.
- D. Section 07200 - Batt and Blanket Insulation.
- E. Section 07920 - Sealants and Caulking.
- F. Section 08800 - Glass and Glazing.

#### 1.03 REFERENCES

- A. AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM):
  - 1. ASTM E-283 - Rate of Air Leakage Through Exterior Windows, Curtain Walls, and Doors.
  - 2. ASTM E-547 - Water Penetration of Exterior Windows, Curtain Walls, and Doors by Cyclic Static Air Pressure Difference.
  - 3. ASTM E-330 - Structural Performance of Exterior Windows, Curtain Walls, and Doors under Uniform Static Air Pressure Difference.
- B. AMERICAN ARCHITECTURAL MANUFACTURERS ASSOCIATION (AAMA):
  - 1. AAMA/WDMA/CSA 101/I.S.2/A440 North American Fenestration Standard/Specification for Windows, Doors and Skylights.
- C. WINDOW & DOOR MANUFACTURERS ASSOCIATION (WDMA):
  - 1. WDMA I.S-4 Industry Standard for Water-Repellent Preservative Treatment for Millwork
- D. AMERICAN NATIONAL STANDARDS INSTITUTE (ANSI)
- E. NATIONAL FENESTRATION RATING COUNCIL (NFRC)

#### 1.04 PERFORMANCE CRITERIA

- A. Pivot Door units shall meet requirements in accordance with AAMA/WDMA/CSA 101/I.S.2/A440.
- B. Air leakage shall not exceed 0.30 cfm per sq.ft. of sash when tested in accordance with ASTM E-283 at 1.57 psf.
- C. No water penetration shall be allowed when tested in accordance with ASTM E-547.
- D. Window units shall withstand positive and negative wind loads without damage. The units shall be tested in accordance with ASTM E-330.

#### 1.05 SUBMITTALS

- A. Shop drawings shall be submitted in accordance with Section 01340.
- B. Product data in the form of general catalogs, test lab reports, product performance, and warranty information shall be submitted in accordance with Section 01340.
- C. Samples showing glazing, quality of construction, and finish shall be submitted in accordance with Section 01340.

#### 1.06 DELIVERY, STORAGE, AND HANDLING

- A. In compliance with Section 01610, door units shall be delivered undamaged and with protective packaging. Complete installation and finishing instructions shall be included.
- B. Store units in a clean, dry place off the ground in an upright position.

# Pinnacle Series

## SELECT PIVOT DOOR

## SPECIFICATIONS

### PART 2 - PRODUCTS

#### 2.01 MANUFACTURER

- A. Pinnacle Select Pivot Door units as manufactured by Windsor Windows & Doors.

#### 2.02 MATERIALS

- A. Frame: Shall be thermally-broken aluminum frame. Interior portions of the jambs and sill shall be clear pine on the wood interior version and painted aluminum on the aluminum interior version. Exterior portion of head and side jambs shall be color-matched extruded aluminum. The optional handicap sill shall be thermally broken bronze or mill aluminum. Available with one panel or one sidelite. Units can be field mulled. Fir interior option is available.
- B. Door Panels: Shall be thermally-broken aluminum. Stiles and rails are 3 7/16" wide, and panel thickness is 3 1/8". Corners shall be mitered. Glazing tape is applied to the back side of glass stops. Doors are shipped knocked down for field assembly. Pine or Fir interior option is available.
- C. Finish: All aluminum exterior and interior surfaces shall be covered with a factory applied, polyester powder-coat paint, available in all Windsor 2604 and 2605 options.
- D. Glazing: Shall be 1-1/4" tempered double pane LoE 366 insulating glass as standard, glazed with double-faced tape, and interior stops. Exterior has glazing gaskets. LoE 270 and Dual LowE options are available. Cardinal's Preserve™ option is available on most glass options. It is a removable, factory-applied protective film adhered to both interior and exterior surfaces of the glass.
- E. Weatherstripping: Frame weatherstripping shall be santoprene rubber with a rigid polypropylene base. This dual-seal weatherstrip seals against both the face and the edge of the panel. It shall be installed in the side jambs, sill, and head for positive protection against air and water infiltration. A self-actuating drop seal automatically deploys when the door is closed, improving weather resistance and reducing sound transmission without dragging on the floor.
- F. Hardware: Installed multi-point hardware has up to 5 locking points as a part of the locking system. Three handlesets are available in black, brushed chrome, brushed stainless, white, and satin nickel. Square ladder pulls, round ladder pulls, recessed handles, and thumbturns are also available. A door closure is built into the top of the panel to control the speed of the swing.
- G. Screens: Not available as a factory option
- H. Grilles: Not available as a factory option

# Pinnacle Series

## SELECT PIVOT DOOR

## SPECIFICATIONS

### PART 3 – EXECUTION

#### 3.01 EXAMINATION

- A. Verify that there is no visible damage to the unit before installation.

#### 3.02 INSTALLATION

- A. Verify the rough opening is of the recommended size and that it is plumb, level, and square.
- B. Install the window unit in accordance with the manufacturer's recommendations.
- C. Install sealant, backing material, and insulation around opening perimeter in accordance with Section 07900 and Section 07920.

#### 3.03 ADJUSTMENT AND CLEANING

- A. Operate unit and verify that all hardware operates freely. Make any adjustments necessary.
- B. Cover the window unit to avoid damage due to spray paint, plaster, and other construction operations.
- C. Remove all visible labels and instructions.
- D. Final cleaning of glass in accordance of Section 01